

## **Notice of Proposed No Further Action**

Chevron 9-1329, 6501 Oakmont Drive  
Santa Rosa, CA /Case No: 1TSR003

**Internet Posting Date: March 20, 2009**

**End of Comment Period: April 20, 2009**

### **Proposed Decision**

This Notice invites the public to review and comment on the pending decision to require no further action in the investigation and cleanup of petroleum hydrocarbon releases at the above-referenced property.

### **Problem Description:**

A service station was constructed at the Chevron, 6501 Oakmont Drive, Santa Rosa, CA (site) in 1967. In 1986, three underground storage tanks (USTs) and one waste oil tank were removed and replaced with two fiberglass USTs. An existing 10,000-gallon fiberglass UST was left in place. Limited soil and groundwater testing performed during the 1986 tank removal documented a release of petroleum hydrocarbons to soil and groundwater. Contaminants detected at the site include TPH-gasoline, TPH-diesel, TPH-motor oil, benzene, toluene, xylenes, ethylbenzene, and MTBE.

### **Corrective Actions Completed:**

In 2004, three fiberglass USTs, one waste oil tank, associated system piping and dispenser islands were removed from the site. Following the UST system removal, over-excavation to the extent feasible of approximately 1300 cubic yards of contaminated soil was performed in the area of the dispenser islands. The contaminated soils were hauled to a permitted disposal site.

Since 1998, groundwater monitoring wells were installed at the site and offsite to the south. Groundwater monitoring results indicate that, with few exceptions since 2006, groundwater quality at the site has either met or is close to meeting water quality objectives. Groundwater from a large capacity irrigation well located 200 feet east of the site was sampled in January 2009 and no contamination was detected.

### **Proposed No Further Action**

This case will be closed unless significant comments or new information are submitted demonstrating that this case does not meet the no further action criteria.

Records for this case are contained in a file identified as Chevron 9-1329, 6501 Oakmont Drive, Santa Rosa, Case No: 1TSR003 and is available for review by calling (707) 576-2220. You may also review information about this site on the Geotracker internet site. For further questions or comments, please contact Jo Bentz at (707) 576-2838 or [jbentz@waterboards.ca.gov](mailto:jbentz@waterboards.ca.gov).